



c/2

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2023/School/491

DATED: 16/10/2023

To,

The Principal,
Holy Heart Secondary School,
F Block Mahavir Enclave,
New Delhi.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Holy Heart Secondary School Located at F Block Mahavir Enclave, New Delhi.

Sir,

Please refer to your Email Dated 14/09/2023. on the subject cited above. In this connection it is to inform you that the above said building has been visited by the officer concerned of this department on 04/10/2023 in the presence of Dr. B.R. Sharma (Manager) for fire safety point of view.

During the course of inspection the following shortcomings are observed:-

1. One staircase of 90 to 150cm width found provided against required two staircases remotest to each other, of 1.5 m clear width.
2. Width of class room doors found varies from 80 cm to 100cm, all the class room doors must have 100 cm clear width.
3. Width of corridors/ exit passages leading to stairs must have clear width of 1.5 m.
4. Hose reel Hoses found provided but nonfunctional.
5. The Terrace pump of 450 lpm found nonfunctional.
6. Overhead water storage tank of 10000 ltrs capacity found empty.
7. Exit signage found not provided.

In view of the above shortcomings Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
(Director)

Delhi Fire Service

OK


16/10/23

Copy to:-Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.