



C-147  
Atul Garg

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2023/NDZ/ 480

Dated: - 13 / 10 /2023

To

Nav Jeevan Adarsh Public School,  
D-Block, Brij Puri,  
Delhi-110094.

**Sub: - Regarding Issuance Fire Safety Certificate in R/o Nav Jeevan Adarsh Public School,  
D-Block, Brij Puri, Delhi-110094.**

Sir,

With reference to your Letter No. Nil Dated 19/08/2023 Outdoor Diary No. 5210 Dated 21/08/2023 on the subject cited above, in this connection, it is to inform you that the premises was inspected by the officer concerned of this department on dated 03/10/2023 in the presence of Sh. Aman Bansal (Manager) and the following shortcomings were observed:-

1. Hose Reel Hose not provided.
2. Fire pump of 220Lit / min. capacity not provided.
3. Over Head tank of 2,500 Ltr. Capacity not provided.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully

  
(ATUL GARG)

DIRECTOR  
DELHI FIRE SERVICE



Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.