

c/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/School/ 494

Dated: 17/10/2023

To,
The Principal,
Kendriya Vidhalaya,
Sector-05, Dwarka,
New Delhi-110078.

Subject: Renewal of Fire Safety Certificate in r/o Kendriya Vidhalaya, Located at Sector-05, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter No. F.School Building/KVDR-5/2023-24/27, dated 13-09-2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 03/10/2023 in presence of Sh. Satish Kumar (Principal) for fire safety point of view.

During the course of inspection the following shortcomings were noticed.

1. The Fire Extinguishers found provided but empty/defective/nonfunctional.
2. Hose Reel Hose found nonfunctional.
3. Terrace pump of 450 lpm found nonfunctional .
4. Exit sign found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter

Yours faithfully,

(Atul Garg)
Director.

Delhi Fire Service

Copy to:-

Directorate of Education Old Secretariat Delhi - 110054