

c/119

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/<sup>School</sup>GH/NDZ/ 2023/ 487

Dated:- 13/10/2023

To,  
The Head of School,  
M/S M.C. Primary Co. Edu. School,  
Bara Hindu Rao, Delhi-06.

**Sub: Regarding issuance of FSC in r/o M.C. Primary Co. Edu. School at Bara Hindu Rao, Delhi-06.**

Sir,

This has reference to your email id <barahinduraomcd@gmail.com> dated 21/09/2023, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 04.10.2023 in the presence of Mrs. Nahid Praveen and following shortcomings are observed.

1. Fire extinguishers are due for refilling.
2. Hose reel found non functional.
3. Pump found non functional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Running school without valid Fire Safety Certificate is at the risk and liability of school management, concerned authority may take action at their end.

Yours faithfully,

  
(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.

