

C-17



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2023/NDZ/ 479

Dated 13/10/2023.

To,

The Principal,
New Bal Jyoti Public School
Gali No.-13, Brahmpuri Delhi-110032.

Sub:- Regarding Issuance Fire Safety Certificate r/o New Bal Jyoti Public School located at Gali No.-
13, Brahmpuri Delhi-110032

Sir,

With reference to your letter N.B.J.P.S dated 13/08/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of above premises from fire safety point of view in presence of Mr. A. D. Bajpai, Manager of the school on dated 11/09/2023. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. First-Aid hose reels not provided.
2. Fire pump on terrace having capacity 220 lpm output 40 meter found removed.
3. Overhead water storage tank capacity 2,500 liters not provided.
4. Exit signages not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar
New Delhi-110053