



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 482

Dated: 13/10/2023

To,

The Principal,
N.R Public School,
RZF-764/1, Near DESU Office, Raj Nagar-II,
Palam Colony, New Delhi-110077.

Subject: Renewal of Fire Safety Certificate in r/o N.R Public School Located at RZF-764/1, Near DESU Office, Raj Nagar-II, Palam Colony, New Delhi-110077.

Sir,


Please refer to your email dated 28-09-2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 06/10/2023 in presence of Sh. Narender Yadav (Employee) for fire safety point of view.

During the course of inspection the following shortcomings are noticed.

1. Staircases found blocked/locked at 3rd floor & terrace level.
2. Hose Reel Hose found nonfunctional.
3. Terrace pump of capacity 450 lpm found nonfunctional & not in auto mode.
4. Overhead tank of capacity 10,000 ltr found empty.
5. Exit sign found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation with this department.

Yours faithfully,


13/10/23
(Atul Garg)
Director,
Delhi Fire Service

13/10/23

Copy to:-

Directorate of Education Old Secretariat Delhi – 110054