

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/MS/DFS/Hospital/2023/SZ/ 4021

Dated 17/10/2023

To

The Authorized Signatory,
Nursing Home at Plot No 4, Block- B-5,
Safdarjung Enclave New Delhi- 110029

Sub: -Regarding issuance of Fire Safety Certificate in r/o Nursing Home at Plot No 4, Block- B-5,
Safdarjung Enclave New Delhi- 110029

Sir,

This has reference with letter received through outdoor diary no 6792 dated 03/10/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.10.2023 in the presence of Dr. Pushpender Bajaj to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 Fire check door not provided at some locations.
- 2 First aid hose reel provided but found nonfunctional.
- 3 Automatic detection system provided but found nonfunctional.
- 4 MOEFA provided but found nonfunctional
- 5 Automatic sprinkler system provided but found nonfunctional.
- 6 Internal hydrant and yard hydrant provided but found nonfunctional.
- 7 Electrician Fire Pump capacity 1620 LPM, Diesel Engine Pump 1620 LPM and Jockey Pump 180 LPM not on auto mode.
- 8 Exit Signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE