



a/32

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2023/ 568

Dated: 16/10/2023

To

The Joint Commissioner of Police (Lic.),
First floor, Police Station Defence Colony,
New Delhi-110049

Sub: **Reg. Issuance of Fire Safety Certificate in r/o M/s Punjab Grill (A unit of Lite Bite Foods Pvt. Ltd), Shop/ Property No. D-16, Second Floor, Defence Colony, New Delhi-110024**

Sir,

This has reference to online MHA portal ID No. 2023100316741 dated 05/10/2023 and ID No. 2023092016162 dated 30/09/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department visited the said premise on 10/09/2023 in the presence of Mr. Rajesh Giri to verify the availability and operability of fire protection system and observed that the said building comprises basement, stilt, ground + three upper floors. The shortcomings observed are as below.

1. There are two exit door having width of 2m (front side) and 1.25m against required width of 1.5m each.
2. First aid hose-reel provided but non-functional.
3. Access to the terrace pump and water storage tank is not provided.
4. Exit signage not provided in escape route.

In view of the above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of owner/occupier. The licensing/statutory authority may take suitable and necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

of & m

Copy to:-

1. Sh. Rohit Aggarwal, M/s Punjab Grill (A unit of Lite Bite Foods Pvt. Ltd), Shop/ Property No. D-16, Second Floor, Defence Colony, New Delhi-110024