



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/Hospital/WZ/ 4009

Dated: 18/10/2023

To,  
Dr. Saurabh Kumar,  
Head of Office,  
Satyawadi Raja Harishchandra Hospital,  
Plot No. 30, Sec-7 A, Narela, Delhi-40.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Satyawadi Raja Harishchandra Hospital, Plot No. 30, Sec-7 A, Narela, Delhi-40.

Sir,  
This has reference to your letter no. F.3(212)/SRHC/H&FW/CT/Fire Service/2011/8559-64 dated 19/09/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said Hospital building has been carried out by officer concerned of this department on 05.10.2023 to see the compliance of the requisite fire safety measures. Sh. S.N Sharma (Supervisor, Electrical) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Basement, Ground & Four upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Internal road of 6 m found obstructed by new construction.
2. First Aid Hose Reels found provided but not functional.
3. Smoke/ Heat detectors provided but not functional.
4. MOEFA found provided but not functional.
5. Internal hydrants & Yard hydrants found provided but not functional.
6. Pumping system not found in auto mode.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)  
Director  
Ph. 011-23414000

9/10

Copy to :-

1. The Executive Engineer, PWD (Electrical), HMED, North Dr. BSA Hospital, Sec. 6, Rohini, Delhi-110085.