



c/63

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2023/ 489

Dated:- 13 /10/2023

To

The Principal,
St. Columba's School,
Ashok Palace, New Delhi.

Sub: Regarding renewal of FSC in r/o St. Columba's School, Ashok Palace, New Delhi.

Sir,

This has reference to your letter no. nil dated 22/09/2023 on the subject cited above. In this regard, it is to inform you that the site was visited by officers concerned of this department on 04.10.2023 in the presence of Smt. Renu Rana and following shortcomings were observed.

1. First aid Hose reel is not covering entire area, required to be extended upto left out area.
2. Hose reel & hydrant are required to be extended in auditorium of middle block also.
3. Ventilation /smoke management system is not provided in the basement.
4. Fire pump not on auto mode provision.
5. Fire retardant paint certificate, on wooden & fabric is required.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Further, running school without valid Fire Safety Certificate shall be at the risk and liability of school management. Concerned authority may take action at their end as deemed fit.

Yours faithfully


(Anul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.