



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C-05

No. F6/DFS/MS/2023/School/ 498

Dated: 18/10/2023

To

The Principal
Pioneer Public School,
A-1 Block, Sant Nagar, Delhi-84.

Sub: - Regarding renewal of fire safety certificate in r/o Crayon Box School located at Khasra No-6/20, Gali No-6, Block-D, Shastri Park Extension, Nathupura, Burari, Delhi-110084.

Sir,

Please refer to your letter no. CBS/9/2023 dated 14.09.2023 received in this department vide outdoor dairy no.6058 dated: 14.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.10.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floors only. At the time of inspection Mr. Nitin Tyagi (Director) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. 02 nos. of continues staircase from ground to terrace level and one side staircase obstruct by fiber sheet needs to be removed.
2. All class room doors size 80cm provided against the requirements of 1.20m.
3. Smoke ventilation system not provided at first floor.
4. Exit signage and floor signage not provided at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director
Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

