



c/39



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2023/School/ 496

Dated: 18/10/2023

To

The Principal  
Sarvodaya Kanya Vidyalaya,  
MalkaGanj, Delhi-110007.

**Sub:-** Regarding issuance of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya, MalkaGanj, Delhi-110007.

Sir,

Please refer to your letter no. SKV/MG/317 dated 14.09.2023 received in this department vide outdoor dairy no.6229 dated: 18.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 06.10.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 old blocks, one block comprised of ground + 03 upper floors & one block comprised of ground + 02 upper floors interconnected with new blocks. At the time of inspection Sh. R.S. Bansal (Estate Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. For assembly occupancy <sup>(Auditorium)</sup> at first floor one additional 02m wide staircase is required.
2. Hose reels provided but not functional.
3. Terrace level fire pumps capacity of 450 lpm provided but not functional.
4. Exit signage not provided at strategic locations in the building.
5. Alternative staircase having width of 2.0m from Auditorium to ground floor need to be provided.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

  
(Atul Garg)  
Director  
Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

16/10