



c/38

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2023/SZ/579

Dated: 20 / 10 / 2023

To

The Joint Commissioner of Police (Lic.),
First floor, Police Station Defence Colony,
New Delhi-110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Bengali Sweets located at Shop No. G-19, South Extension Market, Part-I, New Delhi-110049

Sir,

This has reference to online MHA portal ID No. 2023080213811 dated 28/09/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department conducted inspected of the said premise on 07/10/2023 & 13/10/2023 in the presence of Sh. Ravinder Kumar Jain and observed that previously the eating house running at ground floor only was issued shortcomings by this department vide letter No. F6/DFS/MS/EH/2023/SZ/91 dated 23.02.2023, which found complied. However, the Fire Safety Certificate is now sought for Ground and 1st floor, accordingly the shortcoming observed is as below.

1. The required width of staircases provided is less than the required width of 1.50m each.

In view of the above shortcoming, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of owner/occupier. The licensing/statutory authority may take suitable and necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Sh. Ravinder Kumar Jain, M/s Bengali Sweets located at Shop No. G-19, South Extension Market, Part-I, New Delhi-110049