

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/Industrial/SZ/2023/ 4052

Dated:- 20/10/2023

To,

Sh. Vishav Dhamija (Authorised Signatory),
M/s. Blue Heaven Cosmetics Pvt. Ltd.,
B-104/5, Naraina Industrial Area, Phase- I, New Delhi- 28

Sub: - Regarding renewal of fire safety certificate in r/o M/s. Blue Heaven Cosmetics Pvt. Ltd. located at B-104/5, Naraina Industrial Area, Phase- I, New Delhi- 28.

Sir,

Please refer to Form 'J' dated Nil received in this department through outdoor dairy No. 7032 dated 06.10.2023, on the subject cited above. In this connection this is to inform you that the above mentioned site was inspected by the officer concerned of this department on 11.10.2023. At the time of inspection you were also present at site. During the course of inspection it was observed that the building is comprised of Basement, stilt, ground plus two upper floors. Your request is rejected under Rule 37 (3) due to following shortcomings:-

- 1 The stilt floor is found being used as industrial storage.
- 2 Fire check doors found removed at basement floor.
- 3 MOEFA system found provided but not functional.
- 4 Fire pumps found not in auto mode.

In view of the above shortcomings, the renewal of Fire Safety Certificate' cannot be considered at this stage. You are advised to rectify the above mention shortcomings under intimation to this department for taking further necessary action in this matter.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi- 110005.

otc
h