



No.F6/DFS/MS/Hospital/SZ/2023/ 456

Dated:: 20/10/2023

To,

The Medical Superintendent,
New Nursing Home, Shri Moolchand Khatri Ram Hospital,
Lajpat Nagar-III, New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in r/o New Nursing Home, Shri Moolchand Khatri Ram Hospital, Lajpat Nagar-III, New Delhi.

Sir,

Please refer to your letter received through email ID-Legal@moolchandhealthcare.com dated 04.09.2023 on the subject noted above. In this connection, it is to inform you that the said premises was visited by a team of officers concerned of this department on 13.10.2023 in the presence of Mr. Sachin (Facility Manager) & Mr. Bheesan Singh (Fire Safety Officer) and following shortcomings were observed during the time of inspection:-

1. Heavy leak in piping system of sprinklers.
2. Some of the exits passing through occupied area.
3. No smoke exhaust system found provided in the building.
4. Automatic Fire Detection and Alarming System found not functional.
5. Vertical openings not sealed.
6. Electrical cables must be removed/ segregated from the fire hydrant shaft.
7. Electrical panel in one of the staircases must be relocated/ removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

16/10/23

Copy to:-

1. The Executive Engineer (Bldg.) HQ: South Delhi Municipal Corporation, 9th Floor, Civic Centre, Minto Road, New Delhi-110002