

434.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/SZ/ 502

Dated: 25/10/2023

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
A-Block, Janak Puri, New Delhi-110058.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Govt. Sarvodaya Kanya Vidyalaya, A-Block, Janak Puri, New Delhi-58

Sir,

This has in reference to letter No. Nil dated- 05/10/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 16/10/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Jai Bhagwan (Estate-Manager) was present and it was observed that the school building is comprised of New SPS block is having ground plus three upper floors and have following shortcomings.

1. First Aid Hose reels are provided but not functional.
2. Fire pumps having 450 lpm (2 no's) provided but not functional at terrace.
3. Exits signage's are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atal Garg)

Director

Delhi Fire Service

904-2

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.