

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/2023/ 503

Dated: 25/10/23

Yours faithfull

To,

The Principal, Govt. Sarvodaya Kanya Vidyalaya (New Building), Peera Garhi Village, Delhi-110087.

Subject: -Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya (New Building), located at Peera Garhi Village, Delhi-110087.

Sir,

Please refer to your email dated 25.08.2023 on the subject cited above. In this connection, it is to inform you that the said school building have been re-inspected by the officer concerned of this department on 13.09.2023 in the presence of Sh. Udhvir Singh (Estate Manager). During inspection, it has been observed that the school building is comprised of Ground + .03 Upper floors only served with 01 staircase. Fire Safety arrangements such as fire extinguisher, first aid hose reel, fire pumps, & overhead water tank etc found provided. However the following shortcoming has been observed:-

1. Only one staircase of width 1.50 m is provided against requirement of 02 nos. staircase of 1.5 m width each.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delm - 110054