

C-14.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2023/SZ/ 505

Dated: 25/10/23

To,

The Principal,
M.C.D Primary Girls School,
Qutub Vihar, New Delhi-110071.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M.C.D Primary Girls School,
Qutub Vihar, New Delhi-110071.

Sir,

This has in reference to letter No. Nil dated- 20/09/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 16/10/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Rajender (Principal) was present and it was observed that the school building is comprised of New block is having ground plus two upper floors and have following shortcomings.

1. First Aid Hose reels are provided but not functional.
2. Fire pumps having 450 lpm provided but not functional at terrace.
3. Exits signage's are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Ajai Garg)

Director

Delhi Fire Service

[Handwritten signature]

Copy to:-

1. Director of Education, M.C.D, Civic Centre, Minto Road, New Delhi-110001.