

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/Cosmetic/2023/ 4072
To,

Dated: 23/10/2023

Sh. Rakesh Gulati (Owner),
M/s Sheeba Cosmetics India, T2/199,
Mangol Puri, Industrial Area, Phase-I,
New Delhi-110083.

Sub: Issue of FSC in r/o M/s Sheeba Cosmetics India, T2/199, Mangol Puri, Industrial Area, Phase-I,
New Delhi-110083.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 6569 dated 25.09.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 11.10.2023, in presence of **Sh. Rakesh Gulati (Owner)**, to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 06 fire extinguishers of ABC/Wco2 type provided but found empty.
2. First Aid hose reel provided but not functional.
3. Manually operated electric fire alarm provided but not functional.
4. Automatic sprinkler system in basement provided but not functional.
5. Terrace Fire pump not provided.
6. Approved building plans not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


Atul Garg)
DIRECTOR
Ph; 011-23414000