

e-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/WZ/ 514

Dated: 25/10/2023

To,

The Principal,
Chaudhary Chhoturam Memorial Public School,
Bhagat Singh Park, Siraspur,
Delhi-110042.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Chaudhary Chhoturam Memorial Public School, Bhagat Singh Park, Siraspur, Delhi-110042.

Sir,

This has reference to your letter no. F126/ A 13 dated 22/08/2023 received via outdoor diary no. 6386 dated 21.09.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 10.10.2023 to see the compliance of the requisite fire safety measures. Sh. Arvind Singh Panwar (Principal) was present at the time of inspection.

During the course of inspection it was observed that previously this department had issued FSC for a building comprised of 03 Blocks, 01 Block Ground plus First Floor & 02 Blocks Ground floor only vide letter no. F6/DFS/MS/2018/1304 dated 05/06/2018 but now the school building found comprised of 03 Blocks, 02 Blocks Ground plus First floor & 01 Block of Ground floor only. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

- 1. There is only 01 staircase provided in the newly constructed block of Ground plus first floor against the requirement of 02 staircases of 1.50 m width each.
2. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.


Yours Faithfully


Atul Garg
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.


o/c