

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2023/540

Dated 25/10/2023

To

Addl. Commissioner of Police,
 Licensing Unit 1st Floor,
 P.S Defence Colony,
 New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in respect of M/s Hotel ASKO International Located at 12A/29, Karol Bagh, New Delhi -110005.

Sir,

Please refer to letter No. 2023072913607, dated 09-10-2023 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer from this department on 18/10/2023 in the presence of Sh. Prakash Tiwari (Manager) for the renewal of fire safety certificate.

During course of inspection the following shortcomings were observed:

1. One hour Fire rating Fire Check Doors must be provided at each floor.
2. Smoke exhaust fans found removed in basement.
3. Terrace pump found nonfunctional in auto mode.
4. CO Detectors must be provided in entire guest house.
5. Electric meter must be away from stairs
6. Tin shed found erected at terrace level. It must be removed.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)
 Director
 Delhi Fire Service

Copy to: - The Manager, M/s Hotel ASKO International Located at 12A/29, Karol Bagh, New Delhi -110005.