

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/SZ/ 506

Dated: 25/10/2023.

To,

The Principal,
MCD Primary School (CO-ED),
Budhela Village, Vikaspuri, New Delhi-110018.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. MCD Primary School (CO-ED), Budhela Village, Vikaspuri, New Delhi-110018. (School ID. 1556113)

Sir,

This has in reference to your letter no. Nil dated- 21/09/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 16/10/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Anju Sharma (Principal) was present and it was observed that the school building is comprised of three blocks having A block ground floor, B & C block ground plus one upper floors and have following shortcomings.

1. An additional staircase shall be provided of 1.5 m in block-C.
2. Fire extinguishers provided but not functional.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Anil Garg)

Director

Delhi Fire Service

[Handwritten signature]

Copy to:-

1. Director of Education, M.C.D, Civic Centre, Minto Road, New Delhi-110001.