

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

Dated: 26/10/2023

No. F6/DFS/MS/SZ/2023/ 520

To,

The Principal,
Bal Bharti Public School,
Sector - 12, Dwarka, New Delhi - 110075.

Subject: Renewal of Fire Safety Certificate in r/o Bal Bharti Public School Located at Sector - 12, Dwarka, New Delhi - 110075.

Sir,

Please refer to your email, dated 04/10/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officers concerned of this department on 12/10/2023 in presence of Sh. Sudeep (Estate Manager) for fire safety point of view.

During the course of inspection following shortcomings are observed.

1. Staircases provided for upper floors are found partially blocked/ locked at terrace.
2. The smoke exhaust system provided in the basement is inadequate.
3. Terrace fire pumps found nonfunctional in auto mode.
4. Exit signage's found removed at some places.
5. School activities are seen in porta cabins erected in the premises. The porta cabin must not be used for any purpose without getting Fire Safety certificate from this department.
6. Dully fill form J & K are not submitted.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to; - Directorate of Education Old Secretariat Delhi - 110054.