

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2023/SZ/EH/581

Dated 26/10/2023

To

The Dy. Health Officer, MCD,
Public Health Department,
Aurobindo Marg, Green Park Zone,
Green Park, New Delhi- 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Bercos Restaurant (A Unit of BERCOS MELODY House) at Shop No 12, 13-A, 14 & 17, Second Floor, MGF Metropolitan Mall, Saket, New Delhi-110017

Sir,

This has reference with **MHA Portal ID 2023100616861 dated 11/10/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.10.2023 in the presence of Mr. Vishnu to ascertain the availability and operability of fire protection and fire safety measures as installed in the building. During the course of inspection, the following shortcomings/ observations were noticed:

1. There are two exit doors having width of 1.50 mtr & 1.0 mtr (2nd exit through kitchen not acceptable) against the required width of 1.50 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE