

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2023/ 4104

DATED: 30/10/2023

To,

The President / Secretary  
Ishwar C.G.H.S. Ltd.  
Plot No-4, Sector-12, Dwarka, New Delhi.

**Subject: - Renewal of Fire Safety Certificate in r/o Ishwar C.G.H.S. Ltd. Located at Plot No-4, Sector-12, Dwarka, New Delhi.**

Sir,

Please refer to your letter No ICGHS/2023/23 dated-09/10/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 19/09/2023 in the presence of Sh. Anand Jha (Manger) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Staircase found partially blocked and locked at terrace level.
3. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers.
4. PA system found nonfunctional.
5. Terrace pump found nonfunctional in auto mode.
6. Exit signage's found removed at some places.
7. Duly filed form J & K are not submitted.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
(Director)  
Delhi Fire Service  
30/10/23

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.