

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2023/Hospital/ 4099

Dated: 30/10/2023

To,

Assistant Director (Admn.)  
Employees' State Insurance (ESI) Hospital,  
Rohini, Sector-15,  
New Delhi-110089.

**Sub:** Issuance of Fire Safety Certificate in r/o ESIC Hospital, Sector-15, Rohini, New Delhi-110089.

This is in reference to your letter No. DM (RH) 115-w/fire-fighting system/2011/Estate/490-A dated 01.06.2023, received through outdoor diary no. 4100 dated 25.07.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **04.10.2023** in presence of **Sh. Savinder Lakra, Admin officer** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. There are total 07 staircases & 01 ramp communicating from ground to upper floors in the Hospital building out of which 01 staircase in admin area found permanently locked.
2. Natural ventilated in some compartments found converted in to Air condition area without smoke management system.
3. First Aid hose reel provided but not functional and not reachable in some areas.
4. Internal / yard hydrant provided but not functional as main line found overhauled for maintenance.
5. Terrace tank of 20,000ltr found not connected with hydrant riser line.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht)  
[tp://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Copy to:

1. The Chief Engineer (PMD) ESIC Head Quarter Office, Panchdeep Bhavan, C.I.G Marg, Delhi-02.
2. Sh. Savinder Lakra, Admin officer.