

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2023/SZ/ 4098
To

Dated:- 30/10/2023

The Authorized signatory,
M/s Farm Bhawan, 14-15, Nehru Place,
New Delhi

Sub: - Regarding issuance of fire safety certificate in r/o M/s Farm Bhawan at 14-15, Nehru Place,
New Delhi

Sir,

This has reference to with letter no 16(8)/NSC-ENGG/FARM BHAWAN/FIRE NOC/23-24 dated 17/08/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.10.2023 in the presence of Mr. Abhishek to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. Smoke management system not provided in the basement.
2. Automatic detection system partly provided at 1st floor of the building.
3. Diesel pump provided but found nonfunctional.
4. Exit Signage found removed at some places.

Keeping in view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL SARG)
DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]