



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

C-23

No. F6 /DFS/MS/School/NDZ/2023/ 517

Dated: 26 / 10 / 2023

To,

The Principal  
Florence Public School  
19-A, Pratap Nagar,  
Mayur Vihar Phase-01,  
Delhi-110091.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Florence Public School located at 19-A, Pratap Nagar, Mayur Vihar Phase-01, Delhi - 110091.**

Sir,

This has a reference to your Outdoor Diary No. 6390 dated - 21.09.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/10/2023 in the presence of Mrs. Bivha Khanna (Principal) and observed that building comprised of Ground + 03 upper floors.

**Following shortcomings were observed during time of inspection:**

1. 02 Staircase of width 1.30 mtrs & 0.80 mtrs are provided against requirements of 1.50 mtrs each.
2. Hose reel hose provided but non functional.
3. Exit Signage's not provided.
4. Water tank capacity of 5,000 liters provided against required capacity of 10,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

o/c @

Copy to: -

1. Director of Education, Govt. of NCT, Old Sectt., Delhi-110054.