



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

Dated: - 30/10/2023

No.F6/DFS/MS/WZ/2023/ 4095

To,

Sh. K M Unni, (General Manager)
M/s. Girdhars International,
F-16 Udyog Nagar Industrial Area,
Peeragarhi, Rohtak Road, Delhi-110041.

Subject: Regarding renewal of Fire Safety Certificate in respect of M/s. Girdhars International, located at F-16, Udyog Nagar Industrial Area, Rohtak Road, Delhi-110041.

Sir,

This has reference to your letter no. nil dated 10/10/2023 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 19/10/2023 in the presence of Sh. K M Unni (GM) & Sh. Pankaj Gautam (HR Manager). During inspection, it has been observed that the said building is comprised of Basement + Ground + Mezz. Floor + 02 Upper Floors served with 02 staircases. The Fire safety arrangement such as fire extinguisher, first aid hose reel, automatic sprinkler system, & overhead water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. Fire Check Doors found removed.
2. Overhead water storage tank 8,000 ltrs. capacity is provided against requirement of 20,000 ltrs. capacity.
3. Lift lobbies are not segregated with fire smoke check door in basement floor.
4. Temporary rooms constructed on the terrace floor shall be removed.

In view of the above shortcomings, renewal of FSC is not considered at this stage & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully,

(Atul Garg)
Director

27/10

27/10/23