

c/65

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2023/EH/ 586

Dated: 27/10/2023

To,

Mr. Mukesh Bansal,
House No.F-198, Prashant Vihar,
Delhi-110085.

Sub: Issue of FSC in r/o M/s Liquid Bar And Lounge LLP, Unit No-101 to 106, FF, D-14, Vardhman Plaza Central Market, Parshant Vihar, New Delhi-85.

Sir,

Kindly reference to online application No. 2023092716473 dated 29.09.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 16.10.2023, in presence of **Mr. Raju (Waiter)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Restaurant found non-functional and second exit staircase found dismantled.
2. First Aid hose reel found provided but not functional.
3. Manually operated electric fire alarm system provided but not functional.
4. Automatic sprinkler found removed at hidden some places.
5. Terrace Fire pump with capacity 450lpm & 180lpm provided but not functional.
6. Terrace water tanks found dismantled and plastic tank provided is less than 5000ltr capacity.
7. Exit signage found removed at some places.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Ajay Garg)
DIRECTOR
Ph; 011-23414000