



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-27



No: F.6/DFS/MS/School/2023/WZ/ 516

Dated: 26/10/2023.

To,

The Principal,  
R.K International School,  
Nizampur, Delhi- 110081.

Sub: - Regarding renewal of Fire Safety Certificate in r/o R.K. International School, Nizampur, Delhi-81.

Sir,

This has reference to your letter no. nil dated 18/09/2023 received via outdoor diary no. 6293 dated 19.09.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 10.10.2023 to see the compliance of the requisite fire safety measures. Sh. Sandeep Kumar was present at the time of inspection.

During the course of inspection it was observed that previously this department had issued FSC for a building comprised of Ground plus First Floor vide letter no. F6/DFS/MS/2020/WZ/SCHOOL/427 dated 15/10/2020 but now the school building found comprised of 02 Blocks inter-connected, 01 Block Ground plus First floor & another block Ground plus three upper floors. Your request for renewal of FSC is rejected due to the following shortcomings:-

1. There is only one staircase provided in Ground+3 Block against the requirement of 2 staircases of width 1.5 m each and both the staircases should reach up to terrace.
  2. First Aid Hose Reels not provided.
  3. Terrace level pump of 450 lpm capacity found not provided.
  4. Overhead tank of 10,000 ltrs capacity found not provided.
  5. Exit Signage's not provided.
  6. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.
- You are advised to rectify the above-mentioned shortcoming under intimation to this department.

Yours Faithfully

(Atul Gang)

Director

Ph. 011-23414000

our

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi. 27/10