

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/CNG/2023/SZ/ 4136

Dated: 03/11/2023

To,

Sh. Pulkit Bhardwaj (Chief Manager),
IGL Bhawan, Plot No.-4, Community Centre,
R.K. Puram, Sector-9, New Delhi-110022.

Sub: - Regarding issuance of Fire Safety Certificate in r/o CNG Station at Khasra No. 43/16 & 44/20/2, Village- Bakargarh, Tehsil-Najafgarh, District -South West, Delhi-110073.

Sir,

This has reference to your letter No. IGL/CNGPRJ/NOC/05102023 dated 05/10/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the Station on 30/10/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Amit Kumar (Manager) was present and it was observed that the station building is comprised of ground floor and have following shortcomings:-

1. Gas and flame detectors are not provided.
2. MOEFA provided but not functional.
3. No smoking boards are not displayed in English and Hindi.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police, 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi-110064.