

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Institute/2023/SZ/ 239

Dated: 31/10/2023

To,

The Executive Engineer (Bldg) HQ,
MCD, 8th Floor, Civic Centre,
Minto Road, New Delhi 110002

Sub: Regarding issuance of Fire Safety Certificate in r/o Deshbandhu College, at F Block, Kalkaji,
New Delhi 110019.

Sir,

This has reference to **online ID 10074435 dated 23/10/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was jointly visited by a team of officers from this department along with a team of MCD Building department on 26.10.2023 in the presence of Mr. Anil Bansal (AE/Bldg) MCD to check the compliance of fire safety arrangements installed in the building from fire safety point of view and following shortcomings/ observations made are as under:

1. Presently, the building is constructed only 1/3 as appraised by the concerned architect and major portion, i.e. 2/3 of the building is yet to be constructed.
2. Only one staircase & one ramp are provided against the required 08 nos of Staircase & one ramp.
3. Most of the fire extinguisher found empty.
4. First aid hose reel provided but found not functional.
5. Manually operated fire alarm system found non functional.
6. Internal hydrant system provided but found not functional.
7. Fire fighting pumps are not working.
8. Overhead tank capacity 10,000 ltrs found empty.
9. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

