

C-47



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 523

Dated: 31/10/2023

To,

The Principal
Govt. Girls Secondary School,
Burari, Delhi-110084.

Sub:- Regarding renewal of fire safety certificate in r/o Govt. Girls Secondary School (School I'd No- 1207117) located at Burari, Delhi-110084

Sir,

Please refer to your letter received through online e-mail dated: 03.10.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 21.10.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, one block comprised of ground + first floor & two blocks comprised of ground + 03 upper floors only. At the time of inspection Mrs. Richa Luthra Gill (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher provided but not functional.
2. Hose reel hose provided but not functional and some nozzles found missing.
3. Terrace level fire pump capacity of 450lpm each block provided but found not functional.
4. Exit signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Aul Carg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.