



F6 /DFS/MS/EH/NDZ/2023/ 4142

Dated 03/11/2023

To,

Dr. Neena Sondhi (Medical Superintendent),  
Jeevan Anmol Hospital,  
Mayur Vihar , Phase -1,  
Opp. Pratap Nagar, Delhi-110091.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Jeevan Anmol Hospital,  
Mayur Vihar , Phase -1, Opp. Pratap Nagar, Delhi-110091.**

Sir,

This has a reference to your outdoor dairy No. 6692 dated 27.09.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 21.10.2023 in the presence of Mr. Jitender Sharma and observed that building comprised of Basement + Ground + 03 upper floors.

**Following shortcomings were observed during time of inspection:**

1. Staircases found blocked with old furniture.
2. Nozzle of Hose Real found Missing at same places.
3. Hose Real provide but not functional.
4. Hose not placed in FHC.
5. Pumps are not on Auto mode.
6. More Exit not signe shall be provided at strategic places.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Director General of Health Services M.O. I/C Nursing Home Cell, GNCT Delhi,  
F-17, Karkardooma, Delhi-110032