



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2023/ 4139

Dated: 03/11/2023

To

Sh. J.S. Chandel (Security Officer),
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Laundry cum Workshop Building, AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This has reference to the email dated 11/10/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected of the said premises on 27/10/2023 in the presence of Sh. Ashok Sharma (Fire Consultant). The shortcomings observed are as below.

1. The staircase in upper floor found blocked with waste material. The waste material was also dumped at terrace, which is a fire hazard.
2. The Fire/Smoke Check Doors found defective in basement.
3. Some of the exhaust fans found non functional in basement.
4. Half of the basement could not be checked as it was locked and blocked.
5. Exit signage found faded and removed at some places.
6. The lift grounding switch found non-functional.
7. Lift signage found removed.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029