

C-51

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 522

Dated: 31/10/2023

To,

The Principal,
Mother Divine Public School,
Pocket- G-31, Sector-03, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Mother Divine Public School, Pocket- G-31, Sector-03, Rohini, Delhi-110085.

Sir,

Kindly reference to online mail dated 16.09.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 17.10.2023, in presence of **Mr. Vijay Sharma** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. 6.0 mtr road all around the building for fire tender movement is not provide.
2. Second staircase not continue to terrace.
3. FCD is not provided in staircases.
4. Manually operated electric fire alarm not provided.
5. Public Address System not provided.
6. Internal hydrants not provided.
7. The required exit signage are not provided.
8. Lift is found under construction.
9. Fire control room not provided.
10. Building is not matching with approved building plan.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR

Ph; 011-23414000