



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2023/HTL/31

Dated: 31/10/2023

To

The Joint Commissioner of Police (Lic.),  
First floor, Police Station Defence Colony,  
New Delhi-110049

**Sub: Reg. Issuance of Fire Safety Certificate in r/o M/s Reliance Brand Limited at Shop No. G-05, Ground Floor, Worldmark-1, Asset No. 11, Hospitality District Aerocity, IGI Airport, New Delhi-110037**

Sir,

This has reference to online MHA portal ID No. 2023092816529 dated 04/10/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department conducted inspected of the said premise on 16/10/2023 from fire safety and means of escape point of view in the presence of Mr. Jitender Chaudhary. The shortcoming observed is as below.

1. The access to second exit door (rear side) having width of 1.40m is through internal door of 0.84m width against required width of 1.50m each.

In view of the above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of owner/occupier. The licensing/statutory authority may take suitable and necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

12/11

Copy to:-

1. Sh. Karan Jagmohan Sachdeva, M/s Reliance Brand Limited, Shop No. G-05, Ground Floor, Worldmark-1, Asset No. 11, Hospitality District Aerocity, IGI Airport, New Delhi-110037