

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/SZ/ 605  
To

Dated 02 / 11 /2023

The Dy. Health Officer, MCD,  
Public Health Officer,  
Aurobindo Marg, Green Park,  
New Delhi 110016

**Sub: -** Regarding issuance of fire safety certificate in r/o M/s TEN Nam Foods OPC Pvt Ltd (Tenzin Chokyi Bhutia) at Entire Ground floor, Vasant Vihar, New Delhi 110057.

Sir,

This has reference to with **MHA Portal 2023080313916 dated 18/10/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 27.10.2023 in the presence of Mr. Karan to verify the fire safety measures installed in the building and observed that restaurant running at Ground Floor only. During inspection, following points were observed:

1. There are two exit doors having width of 1.40 mtr & 1.0 mtr (2<sup>nd</sup> exit through kitchen not acceptable) against the required width of 1.50 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Joint Commissioner of Police (Lic/Branch) 1<sup>st</sup> Floor PS Defence Colony, New Delhi 110049