



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI – 110001**

No.F6/DFS/MS/SZ/2023/ 4162

Dated: 06 11 /2023

To,

The President,  
Friends Circle CGHS Ltd.  
Plot No – 07, Sector – 12, Ph-1, Dwarka,  
New Delhi – 110078.

**Subject: - Renewal of in respect of Friends Circle CGHS Ltd. Located at Plot No – 07, Sector – 12, Ph-1, Dwarka, New Delhi – 110078.**

Sir,

Please refer to your letter No-FCS/Administrator/2023/05 dated -19/10/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 31/10/2023 in the presence of Sh. Ramgopal Soni (Sr. Guard) for fire safety point of view.

**During the course of inspection following shortcomings have been observed**

1. Six meter wide internal road around the building found encroached/ block.
2. Fire check door found removed in basement.
3. Hose reel hose and hydrants found nonfunctional
4. MOEFA found nonfunctional.
5. PA system found nonfunctional.
6. Automatic sprinkler system in basement found nonfunctional.
7. Terrace Pump of 450 lpm with 40m head found nonfunctional and not in auto mode.
8. Exit signage found removed at some places.
9. Communication system & fireman ground switch are provided in the lift but found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

  
(Anil Garg)  
Director  
Delhi Fire Service.  
31/10/23

Copy to:-

The President, Friends Circle CGHS Ltd. Plot No – 07, Sector – 12, Ph-1, Dwarka,  
New Delhi – 110078.