

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2023/SZ/ 558

Dated: ...03/11/2023

To

The Joint Commissioner of Police,
Lic/Unit, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Lords Inn at (Unit of ASKJ Hospitality LLP) at A-10,
Chittranjan Park, CR Park, New Delhi 110019

Sir,

This has reference with **MHA Portal ID 2023080413956** dated **10/10/2023** on the subject cited above. In this connection, this is to inform you that, the existing building is comprised of Basement, ground plus three upper floors, and the guest house is running at Ground & Two upper floors the height of the building is mentioned in the above said MHA Portal application 14.20 mtr and its seems to be wrong.

Keeping in view of above, the management/ owner of the building may please be directed to submit height verification certificate & plans/section/elevation drawings of the building upto last occupied floor as guest house occupancy, for further action in the matter in accordance with the provision contained in Delhi Fire Service Rules, 2010.

This is for your information and further action at your end.

Yours faithfully,

(ATU) GARG
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg Department) Municipal Corporation of Delhi, Central Zone, Lajpat Nagar Jal Vihar, New Delhi 110024 (Ref. MHA Portal ID 2023080413956 dated 10/10/2023)