



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-32

No: F.6/DFS/MS/School/2023/WZ/ 527

Dated: 06/11/2023

To,

The Principal,  
MC Primary Co-ed School,  
Sec A-6, Pocket-5, Narela,  
Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MC Primary Co-ed School, Sec A-6, Pocket-5, Narela, Delhi-110040.

Sir,

This has reference to your email id dated 09.10.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 26.10.2023 to see the compliance of the requisite fire safety measures. Sh. Sanjeev Kumar (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building was comprised of 04 Blocks (01 Block-Ground plus First floor & 03 Blocks Pota Cabin). Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Electric Panel and electric meter are found under the staircase which has to be removed.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

2/11

Copy to:-

1. Director of Education, MCD, Civic Center, New Delhi.