

c/86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/Sdnr/526

Dated: 06/11/2023

To,

The Principal,
Queen's Valley School,
Site-B, Sector - 08, Dwarka, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Queen's Valley School, Located at Site-B, Sector - 08, Dwarka, New Delhi.

Sir,

Please refer to your letter No. QVS/Admin/29/DFS, dated 10/10/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 20/10/2023 in presence of Sh. Sunil (Administrative Head) for fire safety point of view.

During the course of inspection following shortcomings are observed.

1. Staircases provided for upper floors are found locked at terrace.
2. Fire check doors found removed at some places.
3. The smoke exhaust system provided in the basement but it is inadequate.
4. Hose reel hose & hydrants found nonfunctional.
5. Sprinkler system in basement found nonfunctional.
6. Terrace fire pumps found nonfunctional and not in auto mode & all the valves are found closed at terrace.
7. Exit signage's found removed at some places.
8. Basement must be used as per BBL1983.
9. Some temporary rooms are erected in the premises which are not shown in approved plans.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)
Director

Delhi Fire Service

30/10/23

Copy to; -

1. Directorate of Education Old Secretariat Delhi - 110054.
2. The Vice Chairman, DDA, INA, Vikas Sadan, New Delhi.
3. The Commissioner, MCD, Civic Centre, Minto Road, New Delhi -110002.