



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2023/ 4188

Dated: 08 / 11 / 2023

To

Sh. J.S Chandel (Security Officer),
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

**Sub: Renewal of Fire Safety Certificate in r/o JPN Apex Trauma Centre, (AIIMS), Raj Nagar,
New Delhi-110029**

Sir,

This has reference to the email dated 11/10/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected of the said premises on 01/11/2023 in the presence of Sh. Prashant Kumar (JE-Elect.) & Sh. Ashok Sharma (Fire Consultant). The shortcomings observed are as below.

1. Half of the smoke management system in basement found non-functional.
2. Hose reel provided but non-functional in Blk A & inaccessible in basement.
3. Some of the sprinklers are above ventilation duct in basement.
4. The basement found stacked with big cartons/stores.
5. The internal hydrants found non-functional and rusted/corroded.
6. Some of the yard hydrant hose boxes found without hose and nozzles.
7. Fire pumps were not on auto mode.
8. Some of the lifts in Block-A found under repair/maintenance.
9. Lift signage found removed.
10. Waiting area in Block-A was under renovation.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
OK

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029