



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/Indl./ 1172

Dated 07/ 11 /2020

To

The Authorized Signatory
Plot No. 34, Rajasthani Udyog Nagar,
Jahangirpuri, G.T. Karnal Road, Delhi-110033.

Sub: Regarding renewal of Fire Safety Certificate in r/o Industrial building located at Plot 34, Rajasthani Udyog Nagar, Jahangirpuri, G.T. Karnal Road, Delhi-110033.

Sir,

Please refer your letter no-CACI/WKSP/JH/23-24/314 dated 04.10.2023 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 26.10.2023 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no 142 dated 19.03.2020. At the time of inspection Sh. Ravi Arora was also present at site. During the course of the inspection it is observed that the building is comprised of basement, stilt, ground & two upper floors. Your request for FSC is rejected under Rule 35 (3) due to following shortcomings:-

1. Water curtains provided but not functional.
2. Smoke ventilation system provided in basement & all upper floors but not functional.
3. Hose reel hose provided but not functional.
4. Smoke detector provided but not functional.
5. MOEFA system provided but not functional.
6. Sprinkler systems provided in the basement & all upper floors but not functional.
7. Internal hydrant & yard hydrant provided but not functional.
8. All fire fighting pumps are provided in the building but found not functional at the time of inspection.
9. Exits & floors signage's found removed at strategic locational in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department.

Running/ Occupancy of the industry without Fire Safety Certificate is at the rise & responsibility of the management.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Commissioner of Factory licensing, SDMC 3rd, Floor, Civic Centre 3/116
Minto Road, Delhi-110002.