



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/WZ/ 4184

Dated: 08/11/2023

To,

Sh. Rajeev Malhotra,
R G Farm, Budhpur, Alipur,
G.T Road, Delhi- 110036.

Sub: - Regarding renewal of Fire Safety Certificate in r/o R G Farm located at Budhpur, Alipur, G.T Road, Delhi-110036.

Sir,

This has reference to your letter no. nil received via outdoor diary no. 7717 dated 23/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building/ premise has been carried out by officer concerned of this department on 02.11.2023 to see the compliance of the requisite fire safety measures. Sh. Rajeev Malhotra was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground & First floor (First Floor not in use). Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Main entrance gate found obstructed by decorative tents.
2. First Aid Hose Reels provided but not functional.
3. MOEFA found removed/ not provided.
4. Yard hydrant found removed/ not provided.
5. Over Head tank of 10,000 ltrs capacity found provided against the required capacity of 15,000 ltrs.
6. Exit signage's found removed.
7. Form 'J' and 'K' not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000