

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/2023/ 4174

Dated: 07/11/2023

To

The President,
Shri Guru Jambeshwar Sansthan Bhawan,
Civil Line, Behind I. P. College, New Vikas Bhawan II,
Upper Bela Road, Delhi - 54.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Shri Guru Jambeshwar Sansthan Bhawan, Civil Line, Behind I. P. College, New Vikas Bhawan II, Upper Bela Road, Delhi.**

Sir,

This has reference to letter outdoor diary no. 6843 dated 04.10.2023 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 25.10.2023 in the presence of Sh. Mahavir (Manager). During the inspection, following shortcomings were observed:-

1. Hose reel found but not functional.
2. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service 014
Tel: 011-23414000
06/11