

C 49



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/2023/EH/ 612

Dated 08 / 11 /2023

To

The Joint Commissioner of Police/ Lic,  
1<sup>st</sup> Floor, Licensing Unit, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Embassy Hudson (Aargee's Meals & lounges) at 2522, Ground Floor, Hudson Line, Kingsway Camp, Delhi-110009.

Sir,

This has reference to online mha portal I'd. No. 2022071114372 dated 31.10.2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04.11.2023 in the presence of Mr. Rahul (Service Boy) to verify the fire safety measures not installed in the building and observed that the building is comprised of basement, ground & 04 upper floors but restaurant is running at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Second exits door width of 1.50m provided but blocked by grills.
2. Hose reel hose provided but not functional.
3. MOEFA System provided but not functional.
4. Internal hydrants provided but not functional.
5. Terrace level fire pump capacity of 450 lpm provided but not functional.
6. Overhead water storage tank capacity of 20,000ltrs found empty.
7. Exit signage found removed in the restaurant.
8. Standby power supply provided but not functional.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

(Anil Garg)  
Director

Ph: 011-23414000

6/11/23