

C 58

75
आज़ादी का
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/BNQT/2023/SZ/ 237
To

Dated: 07.11.2023

The Deputy Health Officer,
Central Zone, MCD,
Jal Vihar Lajpat Nagar,
New Delhi 110024.

Sub: Regarding issuance of FSC in r/o (Banquet Hal) M/s Eswara Kamdhenu Restaurant Pvt Ltd at Entire Ground Floor of Property No 59/18, R.D Marg, Kalkaji, New Delhi 110019

Sir,

This has reference to with MHA Portal ID 2023102017544 dated 20/10/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 01.11.2023 in the presence of Mr. D.N Joshi to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are 02 exit doors having width of 1.50m & 1.0m. The minimum widths of two exit doors are required 2m/1.50 mtr each as per UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

DN