

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SEVRVICE, NEW DELHI-110001

No. F.6/DFS/MS/Indl./2023/SZ/ 221
To

Dated: 10 / 11 / 2023

The Executive Enginner (Bldg) HQ
9th floor, Municipal Corporation of Delhi,
Civic Center, Minto Road,
New Delhi 110002

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No- J-4, Green Park, Extension, New Delhi.

Sir,

This has reference with **online ID 10103576 dated 30/10/2023** on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 07.11.2023 along with Mr. Jayshanker (JE/Bldg) MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Fire check door not provided in lift lobby as per sanction building plans.
2. Smoke management system not provided in the basement.
3. First aid hose reel provided but found not functional.
4. Automatic sprinkler system provided but found nonfunctional.
5. Internal hydrant provided but found nonfunctional.
6. Terrace level pump capacity 450 LPM provided against the required capacity of 900 LPM.
7. Overhead tank capacity 10,000 ltrs provided against the required capacity of 30,000 ltrs.
8. Exit signage not provided at some places.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE